

NORME INTERNATIONALE

INTERNATIONAL **STANDARD**

62305-2

Edition-1 2004-01

Project: IZRAČUN OCENE TVEGANJA SMEL - VRTEC LAPORJE

Structure's Attributes:

Length of structure (m): 41 Width of structure (m): Height of roof plane (m)*: 9 Equivalent area (m2): 8.210 m2

Structure's Dimensions:

Location relative to surroundings: Similar in height Location density (service line density): Urban Number thunderdays: 41 days/year Equivalent annual flash density: 4,1 flashes/km2

Structure's Attributes:

Risk of fire or physical damage: Ordinary Structure screening effectiveness: Average

Internal wiring type: Unscreened

Protection Measures:

LPS type: Level IV - 84%

Fire protection level: Manual systems Surge protection: Full SPD set IEC62305-4

Conductive Service Lines:

Power Line: Type of service to the structure: Buried cable

Type of external cable: Unscreened

Presence of MV / LV transformer: No Transformer

Other Overhead Services:

Number of conductive services: Type of external cable: Unscreened

Other Underground Services:

Number of conductive services: 4 Type of external cable: Unscreened

Loss Categories:

Category 3 - Loss of Cultural Heritage:

Cultural heritage lost due to fire: No heritage value

Category 1 - Loss of Human Life:

Special hazards to life: Average panic level Life loss due to fire: Commercial, schools...

Life loss due to overvoltages: No safety critical systems

Category 4 - Economic Loss:

Special economic hazards: No special hazards Economic loss due to fire: Office, school

Economic loss due to overvoltage: Museum, school Step - touch potential loss factor: No shock risk Tolerable risk of economic loss: 1 in 1,000 yrs

Indiroct Strike

Calculated

Category 2 - Loss of Essential Services:

Services lost due to fire: No service exist

Services lost due to overvoltages: No service exist

Tolorable

Calculated Risks:

	i olei able	Direct Strike	munect Strike	Calculated	
	Risk Rt	Risk Rd	Risk Ri	Risk R	
Loss of Human Life:	1,00E-05	4,22E-06	2,77E-07	4,50E-06	
Loss of Essential Services:	1,00E-03	0,00E+00	0,00E+00	0,00E+00	
Loss of Cultural Heritage:	1,00E-03	0,00E+00	0,00E+00	0,00E+00	
Economic Loss:	1,00E-03	3,87E-06	2,92E-05	3,31E-05	

Diroct Strike

IEC Risk Assessment Calculator: Version 3.0.3 Database: Version 1.0.6